

Original Article

Tests for Checking the Computer Model of a Three-Phase Transformer or an Inductive Reactor and the Diagram for their Implementation

Pustovetov Mikhail

Department of Electrical Engineering and Electronics, Don State Technical University, Rostov-on-Don, Russia.

mgsn2006@yandex.ru

Received: 14 July 2024; Revised: 05 August 2024; Accepted: 01 September 2024; Published: 30 September 2024;

Abstract - This article proposes and substantiates a practical solution to the issue of determining the type of magnetic core of a three-phase transformer or reactor used in a mathematical model of the device. A three-legged single magnetic circuit is perhaps the most common due to its compactness. But, unlike other core configurations, it also provides strong magnetic links between the winding phases, which affects transient processes, including in unbalanced modes, as well as the ability to limit common mode currents. These circumstances are important for obtaining adequate simulation results.

Keywords - Common mode currents, Inductive reactor, Magnetic core, Mathematical model, Mutual inductance, Simulation, Three phases, Transformer.

1. Introduction

The three-phase power transformer is a widespread and significant element of modern electrical power systems and is part of the electrical equipment of a number of technological installations. An effective modern way of analyzing and designing electrical systems is the use of computer simulation. In this case, the degree of abstractness inherent in a particular mathematical or computer model is important: this determines the permissible scope of application of the developed model. In many cases, researchers are interested in the behavior of a transformer in asymmetrical operating modes.

Mathematical and computer models of three-phase transformers are widely used in various studies [1 - 4]. However, the gap is the lack of methods to check whether there is a magnetic coupling between the phase windings or not. The same issue can also be attributed to the simulation of inductive reactors. Since it is advisable to test the declared capabilities of the model, following the proverb: "Trust, but verify", the results of this work provide such an opportunity regardless of the software underlying the simulation of a three-phase transformer or inductive reactor. This is the novelty of the results of the work. In [5 - 7], the equations of a mathematical model of a three-phase two-winding transformer were published, which allows the computer implementation of all twelve groups of winding connections according to the clock notation system in a relatively simple way.



2. Materials and Methods

Scientists from the Institute of Energy of the Academy of Sciences of Moldova V.A. Bosneaga and V.M. Suslov [8 - 11] in [8] proposed methods for testing the performance of a three-legged core transformer model (a three-phase two-winding transformer with a single magnetic core). The tests are aimed at determining the presence of strong electromagnetic coupling (mutual inductance) between all the phases of the transformer, located on different legs of the magnetic core. Such a coupling is present in a transformer with a three-legged single magnetic core but will be absent in a bank of three single-phase transformers. In four-legged and five-legged transformer designs, mutual inductance between the phases is also present. However, in the absence of non-magnetic gaps in the core legs that do not carry windings, the value of mutual inductance tends to zero [12, 13], which leads to a situation similar to the bank of three single-phase transformers. The test results described below correspond to a transformer with a three-legged magnetic core.

Test mode 1. When a winding located on one of the core's legs is excited, a significant Electromotive Force (EMF) will be induced in the unexcited open windings of the other legs (slightly less than half the applied voltage, in accordance with the transformer parameters). For example, when one phase of the primary winding is excited, the test is carried out with the other two phases of the primary winding open and all phases of the secondary winding open.

Test mode 2. Similar to the previous one, but with short-circuited windings of other legs (in which significant currents arise in the short-circuited windings of unexcited legs). In the model unexcited phases of the primary winding have to be short-circuited to ground. The phases of the secondary winding can be all open, or the secondary winding can be loaded at the rated load.

This paper provides explanations for the experiments providing scheme. In all cases, the computer model of a three-phase two-winding transformer with a three-legged magnetic core has phase A of the primary winding excited - a sinusoidal voltage with an amplitude of 100 V is applied to it. The nonlinearity of the magnetization curve is not taken into account. The model equations correspond to the standard (clock) notation and windings connection Y/Y-0.

The electrical circuit diagram for conducting experiments is shown in Figure 1, where A1, B1, and C1 are beginning terminals of the transformer's primary winding phases; X1, Y1, and Z1 are ending terminals of the transformer's primary winding phases; a2, b2, c2 are beginning terminals of the transformer's secondary winding phases; x2, y2, z2 are ending terminals of the transformer's secondary winding phases. Of course, the author means three-phase transformer's mathematical or computer model terminals.

In the case of Test 1, resistances R1 ... R5 tend to infinity.

In the case of Test 2, resistances R1 and R2 tend to zero. If the secondary winding is open, then R3...R5 tend to infinity. If a load (Rload, Lload) is connected to the secondary winding, then R3...R5 tend to be zero.

Let us carry out Test 2 with the secondary winding open. Then, the equations for the phases of the primary winding will be as follows [5 - 7]:

$$v_{a1} - r_{a1} i_{a1} - L_{\sigma a1} \frac{di_{a1}}{dt} = v_{a01}; \quad (1)$$

$$v_{b1} - r_{b1} i_{b1} - L_{\sigma b1} \frac{di_{b1}}{dt} = v_{b01}; \quad (2)$$

$$v_{c1} - r_{c1} i_{c1} - L_{\sigma c1} \frac{di_{c1}}{dt} = v_{c01}. \quad (3)$$




Fig. 1 Electrical circuit diagram for testing a computer model of a three-phase transformer

At the same time, the author reminds us that phases B and C are short-circuited to ground - no voltage is applied to them. In addition, in phases B and C, the EMF of the magnetization branch is induced.

$$e_{b01} = e_{c01} \approx -\frac{e_{a01}}{2} = \frac{u_{a01}}{2}. \quad (4)$$

Therefore, an author can rewrite the equations for the phases of the primary winding of the transformer as follows:

$$v_{a1} - v_{a01} = r_{a1} i_{a1} + L_{\sigma a1} \frac{di_{a1}}{dt}; \quad (5)$$

$$\frac{v_{a01}}{2} \approx r_{b1} i_{b1} + L_{\sigma b1} \frac{di_{b1}}{dt}; \quad (6)$$

$$\frac{v_{a01}}{2} \approx r_{c1} i_{c1} + L_{\sigma c1} \frac{di_{c1}}{dt}. \quad (7)$$

3. Results and Discussion

With the given parameters of the model, sinusoidal signals with amplitudes were obtained: $V_{b01m} = V_{c01m} = 33.159V$ (these signals are in phase); $V_{a01m} = 66.319V$ (this signal is antiphase to the previous two). It is also necessary to remember that a sinusoidal voltage with amplitude $V_{a1m} = 100V$ is applied to phase A (it is practically in phase with the signal v_{a01}). Calculating the signal amplitude on the left side of the equation for phase A, the author obtains $100 - 66.319 = 33.681 V$. This differs slightly from the signal amplitudes on the left side of the equations for phases B and C and the signals in all phases are in phase. It is not surprising that the currents in all phases of the primary winding of the transformer are almost the same $I_{b1} = I_{c1} = 0.995.I_{a1}$.

Figures 2 and 3 graphically show the results of testing a computer model of a three-phase, two-winding transformer with a three-legged magnetic core. Figure 2 shows the results of test mode 1: EMF in the excited and unexcited phases of the primary winding. Figure 3 shows the results of test mode 2: currents in the excited and unexcited phases of the primary winding with open phases of the secondary winding. Figure 4 shows the results of test mode 2: currents in the excited and unexcited phases of the primary winding at a rated load connected to the secondary winding.

From the analysis of the graphs in Figures 2 to 4, everybody can conclude that the tested computer model meets the performance criteria formulated in [8] in Figure 2 $E_{b1} = E_{c1} = 0.499.E_{a1}$; Figure 3 $I_{b1} = I_{c1} = 0.995.I_{a1}$, and Figure 4 $I_{b1} = I_{c1} = 0.913.I_{a1}$. That is, the model reflects the strong electromagnetic coupling of the phases with each other, ensured by the presence of a three-legged single magnetic circuit. Consequently, the mathematical model of a three-phase transformer described in [5 - 7] is suitable for studying both symmetrical and asymmetrical operating modes.

Laboratory verification of the correctness of the circuit operation results (Figure 1) in test modes on a real three-phase transformer with a three-legged core was successful, confirming the adequacy of the computer simulation results obtained.

The design of the transformer core has an important influence on the value of the zero sequence impedance [12, 13].




Fig. 2 Test mode 1: EMF in the excited and unexcited phases of the primary winding: 1 - e_{a1} , 2 - e_{b1} , 3 - $(-e_{c1})$




Fig. 3 Test mode 2: Currents in the excited and unexcited phases of the primary winding, where curves 1 - \dot{i}_{a1} , 2 - $(-\dot{i}_{b1})$ and $(-\dot{i}_{c1})$. Secondary winding phases are open.




Fig. 4 Test mode 2: Currents in the excited and unexcited phases of the primary winding at a rated load connected to the secondary winding, where curves 1 - \dot{i}_{a1} , 2 - \dot{i}_{b1} and \dot{i}_{c1}

A three-phase inductive reactor differs from a transformer in the absence of secondary windings. As well as a transformer three-phase inductive reactor with a magnetic core can be obtained using: 1) a bank of three single-phase reactors, each on an individual closed magnetic core [14, 15]; 2) a three-phase reactor with a three-legged magnetic core [15]; 3) three-phase reactor with a five-legged [15] or a four-legged magnetic core [16]. Assuming that the parameters of each phase of the inductive reactor are identical (structural symmetry), the equations in matrix form according to Kirchhoff's second law for a bank of three single-phase reactors without taking into account iron losses can be written as:

$$\begin{bmatrix} v_{La} \\ v_{Lb} \\ v_{Lc} \end{bmatrix} = \begin{bmatrix} L + L_{\sigma} & 0 & 0 \\ 0 & L + L_{\sigma} & 0 \\ 0 & 0 & L + L_{\sigma} \end{bmatrix} \times \begin{bmatrix} p \cdot \dot{i}_{La} \\ p \cdot \dot{i}_{Lb} \\ p \cdot \dot{i}_{Lc} \end{bmatrix} + \begin{bmatrix} r & 0 & 0 \\ 0 & r & 0 \\ 0 & 0 & r \end{bmatrix} \times \begin{bmatrix} \dot{i}_{La} \\ \dot{i}_{Lb} \\ \dot{i}_{Lc} \end{bmatrix}, \quad (8)$$

Where: V_{La} , V_{Lb} , V_{Lc} – voltage drop between the beginning and the end of each phase of the reactor due to i_{La} , i_{Lb} , i_{Lc} currents flowing;

r – resistance of phase;

L – phase self-inductance;

L_σ – leakage inductance of phase.

Equations (8) are also valid for three-phase inductive reactors with four- and five-legged magnetic cores [17, 18], the conditions of which are explained in [15]. Due to the fact that in the above reactor designs, magnetic fluxes of any sequence, including zero, are closed along the steel magnetic cores, the circuit parameters for the flow of current of any sequence in phase will also be the same.

Similar equations for a three-phase inductive reactor with a three-legged magnetic core:

$$\begin{bmatrix} v_{La} \\ v_{Lb} \\ v_{Lc} \end{bmatrix} = \begin{bmatrix} L + L_\sigma & M & M \\ M & L + L_\sigma & M \\ M & M & L + L_\sigma \end{bmatrix} \times \begin{bmatrix} p \cdot i_{La} \\ p \cdot i_{Lb} \\ p \cdot i_{Lc} \end{bmatrix} + \begin{bmatrix} r & 0 & 0 \\ 0 & r & 0 \\ 0 & 0 & r \end{bmatrix} \times \begin{bmatrix} i_{La} \\ i_{Lb} \\ i_{Lc} \end{bmatrix}, \quad (9)$$

Where, M – mutual inductance of two phases.

In [15], the relation is accepted

$$M = -L/2 \quad (10)$$

In Equations (9), taking into account (10), the author now pays attention to the fact that for the common mode current in each of the phases, only the leakage inductance remains, which is much smaller than the reactor's self-inductance. This will lead to a very low impedance of the phases of a three-phase reactor with a three-legged magnetic core to common mode currents, which is fraught with a significant increase in the magnitude of common mode currents. Because all phases of the transformer's secondary winding can be open at Test 1 and Test 2, as mentioned above. It is equal to the total absence of secondary winding; the circuit diagram in Figure 1 is suitable for testing not only the three-phase transformer's core construction adopted in the mathematical model but the three-phase inductive reactor's core construction, too.

The difference between core configurations of three-phase inductive reactors can be very significant in the case of their usage as equalizing reactors when the parallel connection of several inverters or active rectifiers, having a common DC link and electrical connection on the AC side, is used [19 - 30]. An example of such a device author shown in Figure 5, where L1 and L2 are equalizing reactors, T – power transformers, connecting active rectifiers with three phase AC grid. The design of the transformer and reactors must ensure, among other things, effective suppression of zero-sequence (common mode) currents.

4. Conclusion

The paper proposes and describes the tool to determine whether a selected computer model of a three-phase transformer or inductive reactor is suitable for use in simulating specific operating conditions of the device. The results presented show that the circuit and tests performed with its help allow determining whether the magnetic core in the studied transformer or inductive reactor model is three-legged or has another configuration. This is particularly important for obtaining correct simulation results for unbalanced operating modes and for limiting zero-sequence currents.




Fig. 5 An example of a parallel connection of several active rectifiers having a common DC link and electrical connection on the AC side

References

- [1] Luís M.R. Oliveira, and A.J. Marques Cardoso, "Modelling and Simulation of Three-Phase Power Transformers," *Proceedings of the 6th International Conference on Modelling and Simulation of Electrical Machines, Converters and Systems (ELECTRIMACS 99)*, Lisbon, Portugal, vol. 2/3, pp. 257-262, 1999. [[Google Scholar](#)] [[Publisher Link](#)]
- [2] Shivkumar V. Iyer, "Modelling and Simulating Transformers," *Modeling and Python Simulation of Magnetics for Power Electronics Applications*, pp. 107-159, 2022. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]
- [3] Mitar Simić, Tomislav B. Šekara, and Srđan Jokić, "Model of Three-Limb Three-Phase Transformer Based on Nonlinear Open Circuit Characteristic with Experimental Verification," *Telfor Journal*, vol. 6, no. 1, pp. 42-47, 2014. [[Google Scholar](#)] [[Publisher Link](#)]
- [4] Alexandr Orlov et al., "Losses in Three-Phase Transformers at Load Balancing," *Revista Espacios*, vol. 38, no. 52, pp. 37-45, 2017. [[Google Scholar](#)] [[Publisher Link](#)]
- [5] M. Yu. Pustovetov, "A Universal Mathematical Model of a Three-Phase Transformer with a Single Magnetic Core," *Russian Electrical Engineering*, vol. 86, pp. 98-101, 2015. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]

- [6] Mikhail Pustovetov, "Power Contour Diagram of the Device for Supplying Auxiliary Loads Onboard DC Locomotive and Methods of Forming its Output Voltage," *International Scientific Conference Energy Management of Municipal Facilities and Sustainable Energy Technologies*, pp. 628-636, 2019. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]
- [7] Pustovetov M. Yu., "Uniformed Mathematical Model of 3-Phase Transformer with Single Magnetic Core and It's Computer Implementation," *Proceedings of the Computer Modeling and Simulation International Scientific and Technical Conference*, Saint Petersburg, Russia, pp. 128-134, 2014. [[Publisher Link](#)]
- [8] V.A. Bosneaga, V.M. Suslov, "Modeling of Three-Phase Three Leg Transformer Devices for Engineering Calculations of Asymmetrical Modes for Different Schemes of Winding Connections," *Problemele Energeticii Regionale*, vol. 22, no. 2, pp. 38-50, 2013. [[Google Scholar](#)] [[Publisher Link](#)]
- [9] V. Bosneaga, and V. Suslov, "Transformer Device for Flexible Connection of Asynchronous AC Power Systems Using Semiconducting Switching with PWM," *2017 International Conference on Modern Power Systems (MPS)*, Cluj-Napoca, Romania, pp. 1-5, 2017. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]
- [10] V.M. Suslov, and V.A. Bosneaga, "Method of Parameters Determination for Multi-Winding Transformer Equivalent Circuit in the Form of Multi-Beam Star," *2019 8th International Conference on Modern Power Systems (MPS)*, Cluj-Napoca, Cluj, Romania, pp. 1-4, 2019. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]
- [11] V. Bosneaga, and V. Suslov, "Investigation of Supply Phase Failure in Phase-Shifting Transformer with Hexagon Scheme and Regulating Autotransformer," *2021 International Conference on Electromechanical and Energy Systems (SIELMEN)*, Iasi, Romania, pp. 1-6, 2021. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]
- [12] Admin, Zero Sequence Impedance of Core and Shell Type Wye Wye Transformer, Voltage Disturbance - Power Engineering Experts, 2020. [Online]. Available: <https://voltage-disturbance.com/power-engineering/zero-sequence-impedance-of-core-and-shell-type-wye-wye-transformer/>
- [13] IEEE C57.105-2019, Guide for Application of Transformer Connections in Three-Phase Electrical Systems, IEEE Standards Association, 2020. [Online]. Available: <https://standards.ieee.org/ieee/C57.105/6121/>
- [14] Ramkrishan Maheshwari et al., "Analysis and Modelling of Circulating Current in Two Parallel-Connected Inverters," *IET Power Electronics*, vol. 8, no. 7, pp. 1273-1283, 2015. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]
- [15] Ying Jiang et al., "Research on the Comparison Analyses of Three-Phase Discrete and Integrated LC Filters in Three-Phase PV Inverter," *International Journal of Photoenergy. Special Issue Photovoltaic Materials and Devices*, vol. 2013, pp. 1-14, 2013. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]
- [16] Michael Owzareck et al., "Calculation Method for Four-Legged Inductors of Sine-Wave Filters in Drive Systems," *PCIM Europe Digital Days 2021 - International Exhibition and Conference for Power Electronics, Intelligent Motion, Renewable Energy and Energy Management*, pp. 1-8, 2021. [[Google Scholar](#)] [[Publisher Link](#)]
- [17] International standard IEC 60076-6, Power Transformers - Part 6: Reactors, International Electrotechnical Commission, 2007. [Online]. Available: <https://webstore.iec.ch/en/publication/604>
- [18] Four Leg Choke for Common-Mode Rejection. [Online]. Available: <https://www.schmidbauer.net/en/products/four-leg-choke>
- [19] Yan Jiang et al., "Control of Circulating Current in Parallel Three-Phase Inverter in MW Wind Power System," *2010 International Conference on Electrical Machines and Systems*, Incheon, Korea (South), pp. 133-136, 2010. [[Google Scholar](#)] [[Publisher Link](#)]
- [20] Zheng Wang et al., "Field-Oriented Control and Direct Torque Control for Paralleled VSIs Fed PMSM Drives with Variable Switching Frequencies," *IEEE Transactions on Power Electronics*, vol. 31, no. 3, pp. 2417-2428, 2016. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]
- [21] Kai Li et al., "Research on the Control of Zero-Sequence Circulating Current of Paralleled Inverters Based on Dual-Carrier Modulator and PR Control," *2014 IEEE Conference and Expo Transportation Electrification Asia-Pacific (ITEC Asia-Pacific)*, Beijing, pp. 1-7, 2014. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]
- [22] Zhi-Xiang Zou et al., "Interleaved Operation of Two Neutral-Point-Clamped Inverters with Reduced Circulating Current," *IEEE Transactions on Power Electronics*, vol. 33, no. 12, pp. 10122-10134, 2018. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]

- [23] Kun Xing et al., "Interleaved PWM with Discontinuous Space-Vector Modulation," *IEEE Transactions on Power Electronics*, vol. 14, no. 5, pp. 906-917, 1999. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]
- [24] Seung-Yong Lee, and Jae-Jung Jung, "The Circulating Current Reduction Control Method for Asynchronous Carrier Phases of Parallel Connected Inverters," *Energies*, vol. 15, no. 5, 2022. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]
- [25] Yiwei Ma et al., "Circulating Current Control and Reduction in a Paralleled Converter Test-Bed System," *2013 IEEE Energy Conversion Congress and Exposition*, Denver, CO, USA, pp. 5426-5432, 2013. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]
- [26] Zhihong Ye et al., "Control of Circulating Current in Two Parallel Three-Phase Boost Rectifiers," *IEEE Transactions on Power Electronics*, vol. 17, no. 5, pp. 609-615, 2002. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]
- [27] Ibrahim Ahmad Abubakar, D. Anitha, and R. Brindha, "Performance Analysis of Parallel Connected Inverters Using Different Modulation Techniques," *International Journal of Engineering Research & Technology*, vol. 8, no. 5, pp. 771-775, 2019. [[Publisher Link](#)]
- [28] Hadi A Porkia, Jafar Adabi, and Firuz Zare, "Elimination of Circulating Current in a Parallel PWM Rectifier Using an Interface Circuit," *IEEE Transactions on Power Electronics*, vol. 37, no. 1, pp. 264-273, 2022. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]
- [29] S.K. Mazumder, "Continuous and Discrete Variable-Structure Controls for Parallel Three-Phase Boost Rectifier," *IEEE Transactions on Industrial Electronics*, vol. 52, no. 2, pp. 340-354, 2005. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]
- [30] Robert Smolenski et al., "Compensation of CM Voltage in Systems Consisting of Interleaved AC-DC Converters," *2014 IEEE 23rd International Symposium on Industrial Electronics (ISIE)*, Istanbul, Turkey, pp. 1996-2001, 2014. [[CrossRef](#)] [[Google Scholar](#)] [[Publisher Link](#)]